


# ENTSO-E Winter Outlook 2018/2019

European Network of Transmission System Operators  
for Electricity (ENTSO-E)

Electricity Coordination Group - 23 January 2018

---

# Different risks addressed with different timeframes



# What do the outlooks tell you?



Role of interconnections



Influence of external factors: weather, hydro reservoir level, market conditions, consumer behaviour, robustness against gas disruption...



Sensitivity analysis: look for severe case scenario (1 out of 20 years) & see how system reacts



Review of the previous season for a deeper understanding and improvements

# Seasonal Outlooks- Stepwise approach

Inputs from TSOs and pan-European databases



European constraining scenarios

synchronous peak  
(upward) → Wednesdays 7 pm

low demand with high RES  
(downward) → Sundays 5 am and 11 am




Focused analysis on weeks flagged at risk

Probabilistic approach using numerous situations (temperature, wind, simultaneous severe conditions...)


Aim is to estimate the probability that an issue could occur

Main drivers are identified (evolution of the generation mix, decrease of network/generation availabilities...)

# Lack of margin is not a blackout



# Evolution of Europe's generation mix



**Gas power plant capacity has increased after a fall recorded last winter**

**Acceleration of new RES installation**

**Fossil fuel generation steadily declining**

# Winter Outlook Context


Unforeseen maintenance, delayed return to operation together with countermeasures are considered



Nuclear unavailability



Countermeasures




Hydro reservoir levels near average in Europe\*

But low river levels in south Germany



(\*) Observed Countries: Italy, France, Spain, Switzerland, Austria and Norway




# Winter Outlook- Severe Conditions



Adequacy at pan-European synchronous peak demand time




Out of market measures excluded



Adequacy to monitor closely in a region including Belgium, France, Northern & Centre-North Italy, and Slovenia

**Regional cooperation is a key** – potential need for out of market measures



Country self-sufficient and prone to export from market perspective

Country self-sufficient but prone to import from market perspective

Country required to import from an adequacy perspective


Part of deficit cannot be covered with imports




# Probabilistic assessment on week 3 of 2019

## Vigilance needed in case of cold spell


Belgium



France




Italy (Northern & Central-North)



● No need to import    ● No deficit after import    ● Deficit after import

# Regional Coordination is key – example in CWE



# What for future Seasonal Outlooks?

Prepare future implementation of Clean Energy Package,  
especially Risk Preparedness Regulation (e.g. methodology drafting)

Extend coordination with Regional Security Coordinators  
for short-term adequacy

Prepare further steps for Seasonal Outlook full probabilistic hourly modelling  
in similar way as performed in Mid-term Adequacy

**Thank you for your attention**

---

# Continental Europe - frequency deviations on 10 January 2019


---

Causes determined so far:

1. Energy schedules change at 9pm that created the Deterministic frequency Deviations effect
2. Mismeasurement error on TenneT DE – APG interconnection line
3. EMS - KOSTT issue and the imbalances that are in place since mid January 2018

On 10 January, Continental Europe TSOs experienced a **grid incident** → there was **no Critical Grid Situation and no Crisis**

# System Operations Guideline – System States classification



- The incident was a **Scale 1** because the **maximum frequency deviation was 185 mHz** (below the 200 mHz → threshold for Scale 2).
- The drop in frequency was deep enough to trigger the automatic activation of interruptible load, about 1500 MW was disconnected from the French grid, which is about 2% of RTE's load at the moment when the incident occurred. This means that also the thresholds of the criteria for scale 1 incident on load (L1) were reached.

## ENTSO-E Investigation process ongoing

- Regional Group Continental Europe TSOs were in contact constantly to solve the frequency deviations
- Extraordinary Calls were initiated on weekly basis with the Continental Europe TSOs
- Regional Group Continental Europe Plenary is being provided with reports by:
  - the Coordination Centers (Amprion and Swissgrid) that monitor the frequency values and quality all over Europe
  - The Coordinated System Operations subgroup that will provide an overview of the incident recorded between 9 and 11 January 2019, including improvement measures that can be applied by CE TSOs to avoid similar situations
  - TenneT Germany that will provide an analyses of the German block event when a tie line measurement was frozen
- ENTSO-E Communication department is following closely all media queries and provides feedback in a coordinated way with all involved TSOs.
- On 7 February, RG CE Plenary will meet and provide additional guidance on covering all open items related to the frequency deviations recorded in January 2019 and mitigation measures to be put in place to avoid similar events.